

# PCRL02,

PCRL04,PCRL05,PCRL06,PCRL07,PCRL09,PCRL010,

PCRL011 Radar level meter

# Features

- Small antenna size, easy to install;
  Non-contact radar, no wear, no pollution.
- Almost no corrosion, bubble effect; almost not affected by water vapor in the atmosphere, the temperature and pressure changes.
- Serious dust environment on the high level meter work has little effect.
- A shorter wavelength, the reflection of solid surface inclination is better.
- Beam angle is small, the energy is concentrated, can enhance the ability of echo and to avoid interference.
- The measuring range is smaller, for a measurement will yield good results.
- High signal-to-noise ratio, the level fluctuation state can obtain better performance.
- High frequency, measurement of solid and low dielectric constant of the best choice.

#### Notes:

1 Do not touch the diaphragm with hard objects, which may cause damage to the diaphragm.

2 Please read the Instruction Manual of the product carefully before installation and check the relevant information of the product.

3 Strictly follow the wiring method for wiring, otherwise it may cause product damage or other potential faults.

4 Misuse of the product may cause danger or personal injury.



## **Product overview**

This series of radar level meter adopted 26G high frequency radar sensor, the maximum measurement range can reach up to 60 meters. Antenna is optimized further processing, the new fast microprocessors have higher speed and efficiency can be done signal analysis, the instrumentation can be used for reactor, solid silo and very complex measurement environment.

#### Notes:


- 1 Do not misuse documentation.
- 2 The information presented in this product sheet is for reference only. Do not use this document as a product installation guide.3 Complete installation, operation, and maintenance information is
- provided in the instructions of the product.

4 Misuse of the product may cause danger or personal injury.



# Principle

Radar level transmitter antenna microwave pulse is narrow, the downward transmission antenna. Microwave exposure to the medium surface is reflected back again by the antenna system receives, sends the signal to the electronic circuit automatically converted into level signals (because the microwave propagation speed, electromagnetic wave to reach the target and the reflected back to the receiver this time is almost instantaneous).



Datum measurement: Screw thread bottom or the sealing surface of the flange.

#### Note:

Make sure the radar level meter the highest level cannot enter the measuring blind area (Figure D shown below).



# **Product Introduction** in mm For liquid PCRL02 Application: Slightly corrosive liquid Measuring Range: 10 meters Process Connection: Thread, flange Medium Temperature: -40°C ~ 130°C Process Pressure: -0.1 ~ 0.3MPa Accuracy: ± 5mm Protection Grade: IP67 Frequency Range: 26GHz Signal Output: 4... 20mA/HART (Two-wire / Four) RS485/ Modbus PCRL04 Application: Slightly corrosive liquid, volatile liquid tank Measuring Range: 20 meters Process Connection: Flange Medium Temperature: $-40^{\circ}$ C ~ $130^{\circ}$ C (Standard), $-40^{\circ}$ C ~ 250°C (High temp type) Process Pressure: -0.1 ~ 2MPa Accuracy: ± 3mm Protection Grade: IP67 Frequency Range: 26GHz Signal Output: 4... 20mA/HART (Two-wire / Four) RS485/ Modbus



	Application: Hygienic liquid storage tank, highly corrosive	
PCRL09	tank	
	Measuring Range: 20 meters	
	Process Connection: Flange	
	Medium Temperature: -40°C ~ 130°C (Standard),	
000	-40°C ~ 200°C (High temp type)	
	Process Pressure: -0.1 ~ 4MPa	
	Accuracy: ± 3mm	
	Protection Grade: IP67	
	Frequency Range: 26GHz	
	Signal Output: 4 20mA/HART (Two-wire / Four)	
	RS485/ Modbus	
PCRL10		
	Application: Rivers, lakes, shoals	
	Measuring Range: 30 meters	
C.C.C.	Process Connection: Thread, flange	
Contraction of the second	Medium Temperature: −40°C ~ 100°C	
	Process Pressure: Natural pressure	
	Accuracy: ± 3mm	
	Protection Grade: IP65/ IP67	
	Frequency Range: 26GHz	
	Signal Output: 4 20mA/HART (Two-wire / Four)	
	RS485/ Modbus	

<b>W</b> rsensor	
PCRL11	
	Application: Rivers, lakes, shoals
	Measuring Range: 70 meters
C.	Process Connection: Thread, flange
A LEAST AND A LEAS	Medium Temperature: -40 °C ~ 100 °C
	Process Pressure: Natural pressure
	Accuracy: ± 10mm
	Protection Grade: IP65/ IP67
	Frequency Range: 26GHz
	Signal Output: 4 20mA/HART (Two-wire / Four)
	RS485/ Modbus
For powder, granules, lumps	Application: powder, granules, lumps
PCRL05	
	Measuring Range:
	DN80: granules 12 meters, lumps 12 meters;
	DN100:powder 20 meters, granules 25 meters, lumps 25
	meters; DN125:powder 45 meters, granules 35 meters, lumps 40
Parties-	meters;
	Process Connection: Standard flange, universal flange
	Medium Temperature: $-40^{\circ}$ ~ $130^{\circ}$ (Standard),
	-40 °C ~ 200 °C (High temp type)
	Process Pressure: -0.1 ~ 4MPa(Standard flange),
	-0.1 ~ 0.3MPa(Universal flange)
	Accuracy: ± 15mm
	Protection Grade: IP65/ IP67
	Frequency Range: 26GHz
	Signal Output: 4 20mA/HART (Two-wire / Four)
	RS485/ Modbus

Visensor			
PCRL06	Application: powder, granules, lumps		
	Measuring Range:		
	196mm :powder 35 meters, granules 40 meters, lumps 40		
	meters;		
E C	246mm :powder 45 meters, granules 50 meters, lumps 50		
1	meters;		
TAL AND	Process Connection: Thread, universal flange		
	Medium Temperature: -40℃ ~ 130℃ (Standard),		
	-40°C ~ 200°C (High temp type)		
	Process Pressure: -0.1 ~ 0.3MPa		
	Accuracy: ± 15mm		
	Protection Grade: IP67		
	Frequency Range: 26GHz		
	Signal Output: 4 20mA/HART (Two-wire / Four)		
	RS485/ Modbus		
PCRL07	Application: powder, granules, lumps		
	Measuring Range:		
	DN80: granules 8 meters, lumps 8 meters;		
	DN100:powder 12 meters, granules 15 meters, lumps 15		
-	meters;		
THE REAL PROPERTY AND ADDRESS OF THE REAL PROPERTY ADDRESS OF THE REAL	DN125:powder 15 meters, granules 20 meters, lumps 20		
	meters;		
	Process Connection: Standard flange, universal flange		
	Medium Temperature: -40°C ~ 130°C (Standard),		
	-40℃ ~ 200℃(High temp type)		
	Process Pressure: -0.1 ~ 4MPa(Standard flange),		
	-0.1 ~ 0.3MPa(Universal flange)		
	Accuracy: ± 15mm		
	Protection Grade: IP67		
	Frequency Range: 26GHz		
	Signal Output: 4 20mA/HART (Two-wire / Four)		




**Installation Requirements** 


# Installation guide:


Be installed in the diameter of the 1/4 or 1/6. Note: The minimum distance from the tank wall should be 200mm.

Note: ① Datum ② The container center or axis of symmetry









The top conical tank level, can be installed at the top of the tank is intermediate, can guarantee the measurement to the conical bottom.

A feed antenna to the vertical alignment surface. If the surface is rough, stack angle must be used to adjust the angle of cardan flange of the antenna to the alignment surface.

(Due to the solid surface tilt will cause the echo attenuation, even Loss of signal.)


# Typical installation errors:

Conical tank cannot be installed above the feed port. *Note*: outdoor installation should adopt sunshade.



The instrument cannot be installed in the arched or domed roof intermediate. In addition to produce indirect echo is also affected by the echoes. Multiple echo can be larger than the real value of signal echo, because through the top can concentrate multiple echo. So cannot be installed in a central location.

- ① Correct
- 2 Error




There are obstacles affecting measurement needed reflection plate.

- ① Correct
- 2 Error


The reflecting plate is the role of refraction disturbance signal.

1



# Height of nozzle:

Antenna extends into the tank at least 10mm distance.






**Electrical Connection** 

# The power supply voltage:


(4~20)mA/HART (Two wire system)	The power supply and the output current signal sharing a two core shield cable. The supply voltage range see technical data. For intrinsically safe type must be a safety barrier between the power supply and the instrument.
(4~20)mA/HART(Four wire system)	Separate power supply and the current signal, respectively using a two-core shielded cable. The supply voltage range see technical data.
RS485 / Modbus	Power supply and Modbus signal line separated respectively using a two-core shielded cable, the power supply voltage range see technical data.

### **Connection mode:**

24V two wire wiring diagram as follows:




220V four wire connection is as below:





24V RS485/Modbus wiring diagram as follows:



#### Safety instructions:

Please observe the local electrical code requirements!


Please comply with local requirements for personnel health and safety regulations.

All electrical components of instrument operation must be completed by the formal training of professionals.

Please check the instrument nameplate to provide product specifications meet your requirements. Please make sure that the power supply voltage and instrument nameplate on the requirements.

#### Protection grade:

This instrument meets the protection class IP66/67 requirements, please ensure the waterproof cable sealing head. The following diagram:



#### How to install to meet the requirements of IP67:

Please make sure that the sealing head is not damaged.

Please make sure that the cable is not damaged.

Please make sure that the cable for use with electrical connection specification.

Cable into the electrical interface before its curved downward, ensure that the water will not flow into the

shell, see the 1



Tighten the cable seal head, see the 2Please electrical interface will not use blind plug tight, see the 3

## Instrument Commissioning


# There are three kinds of debugging method:

- 1) Display / Keyboard
- 2) Host debugging
- 3) HART handheld programmer

## Display / Keyboard:

Please debug the instrumentation by four buttons on the display screen. There are three debug menu languages optional. After debugging is generally used only for display, through the glass window can read measured value very clearly.


### Display / Keyboard



## PC debugging:


Connected to PC by HART


- ① RS232 interface or USB interface
- 2 Radar level meter
- ③ HART adapter
- (4) 250  $\Omega$  resistor






# The outer shell:













# PCRL02















PCRL11



Flange type:



ApertureL




**Technical Parameters** 

The outer shell				
The seal between the shell and the	shell cover	Silicone rubber		
Casing window		Polyca	arbonate	
The ground terminal		Stainless steel		
The power supply voltage				
Two wire system				
The standard type	(16 ~ 26) V DC			
Intrinsically safe	(21.6 ~ 26.4) V DC			
Power dissipation	max 22.5mA / 1W			
Allowable ripple				
	- <100Hz		Uss <iv< th=""></iv<>	
	- (100~100K) Hz		Uss <l0mv< th=""></l0mv<>	
The cable parameters				
Cable entrance / plug	1	M20xL5 ca	ble entrance	
Casie entrance / ping	1			
Terminal	·		cross section 2.5mm <sup>2</sup>	
Output parameters				
The output signal	()	~ ~ 20) mA/RS	485	
Communication protocol	•	ART		
Resolution				
Fault signal		1.6µA		
	Constant current output; 20. 5mA 22mA			
The integral time		3.9mA (0 ~ 36) s, adjustable		
	(0	50 <i>)</i> 3, aujus		
Blind area	the ends of the antenna			
The maximum distance measurement  70 meters				
Microwave frequency	20	6GHz		
Communication interface	HART communication protocol			
The measurement interval	about 1 second (depending on the parameter settings)			
Adjust the time	about 1 sec	ond (dependii	ng on the parameter settings)	
Display resolution	1 mm			
Working storage and transportation temperature $(-40 \sim 10)$			<b>(-40∼100)</b> °C	
<b>Process temperature</b> (the temperature of the antenna part) $(-40 \sim 25)$			(-40∼250)℃	
· · · ·	•	-	· · · ·	



Pressure	Max.4MPa
Seismic	Mechanical vibration I0m/s², (10 ~ 150) Hz



Wotian reserves the right to make any change in this publication without notice. The information provided is believed to be accurate and reliable as of this product sheet.

# **Contact us**

Nanjing Wotian Technology Co.,Ltd. Website: www.wtsensor.com Add: 5 Wenying Road, Binjiang Development Zone, Nanjing, 211161, China E-mail: dr@wtsensor.com